



ASSOCIAZIONE PER LA CERTIFICAZIONE
DELLE APPARECCHIATURE ELETTRICHE

Via Tito Livio, 5 - 24123 BERGAMO (Italy)
Tel. +39 035 4175244 e-mail: acae@acaeon.it

Certificate of conformity n° A 15.035

page 1 of 2

Apparatus: Low-voltage tap-off unit 1000V (U_n) – 210/400/630A (I_{n1}) – 30-60Hz (f) – 1000V (U_1) – 4kV (U_{imp}) – 7kA, 1s (I_{sc}) – 30kA (I_{sc}) at 420V – IP33 – 3P+N+1/2E and Aluminium Housing

Designation: GGD-GS 4-630 A PLUG-IN TOB

Manufacturer: GERSAN ELEKTRİK TIC. ve SAN. A. Ş.
Anadolü Yakasi Organize Sanayi Bölgesi Gazi Bulvarı No. 39-41 – P.K. 57
34953 TUZLA – İSTANBUL (Turkey)

Applicant: GERSAN ELEKTRİK

Tested by: VEIKI-VNL – BUDAPEST (Hungary)
LVT – ANKARA (Turkey)

The apparatus, constructed in accordance with the description mentioned in the documents listed on this Certificate has been subjected to the series of proving tests in accordance with IEC 60439-2 (2005-09) and IEC 61439-6 (2012-05).


The results of the tests carried out fulfil the requirements of the relevant parts of IEC 61439-6 (2012-05), according to sub. 10.1 of IEC 61439-1 (2009-01).

The results are shown in the attached documents according to ACAE procedures. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the characteristic assigned by the manufacturer as stated in the following.

The General Secretary

Date: 2015.03.29

ACAE is member of:



MEMBER OF

European of EN, IEC and IEC
Mutual Recognition Agreements

