

ASTA

CERTIFICATE OF COMPLETE COMPLIANCE

Laboratory Ref. No. 1634.2080616.718

Certificate No. 16939

APPARATUS: 8000 A / 400 V / 500 V (L, / LL, / LL), 50 Hz. Rubber turning system, three phase four brush system - R and PE (grounding)

DESCRIPTION: 625 30000

MANUFACTURER: KIRGANE Electric Tls. ve San. A. S.
Tuzla Manufaktur Olg. San. Bldg.
Sahitkadi, no. 8
P.A.S.T. TULIZLA-ISTANBUL,
TURKEY

TESTED BY: Institut „Friedrich für elektrische Hochspannungstechnik“ GmbH
Landsberger Allee 276A
10585 Berlin, GERMANY

DATES OF TESTS: 02 September to 07 October 2008

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this certificate has been subjected to the series of proving tests in accordance with:

IEC 60439-2:2000-16, Sub-clauses 8.2.1, 8.2.2, 8.2.3, 8.2.4, 8.2.5, 8.2.7,
8.2.8, 8.2.9, 8.2.10, 8.2.11, 8.2.12, 8.2.13, 8.2.14 and 8.2.15

The results are shown in the record of Proving Tests and the corresponding attached forms. The values obtained and the general performance are considered to comply with the above statements and to fulfil the ratings assigned by the manufacturer as stated below:

For ratings assigned by the manufacturer and proved by test see Pages 1 and 2.

The record of Proving Tests applies only to the apparatus tested. The responsibility for conformity of any apparatus bearing the same designations with that tested rests with the Manufacturer.

This Certificate comprises: 01 pages, 1 diagram, 1 certificate, 12 photographs, 8 drawings and no other items.

Only signed members of the Certificate, or representatives of the user authorised by any agency on which are stated the assigned rated characteristics of the apparatus tested, are permitted without written permission from ASTA, ASTA Certification Services, either direct, Government Bodies, Rights Representatives, IECB Ltd, United Kingdom.



[Signature]
17th June 2009

ASTA Observer
J. Kemp
Certification
Manager

Date