

ASTA

CERTIFICATE OF COMPLETE COMPLIANCE

Laboratory Ref. No. 1824.2000008.719 Certificate No. 17247

APPROXIMATE: 4000 A / 4000 W / 1000 V-5, 7, 12, 13, 50 Hz Suction trucking system.
Three-phase main busbar system + M and PE (housing)

DESIGNATION: 100-K000A

MANUFACTURER: GERSHAF Elektro-Teil- und San. A. B.
Tuzla Manufaktur Gm. San. Anlagen
Immerstr. 100, No. 8
P.O. Box 7025A-ISTANBUL
TURKEY

TESTED BY: Institut „Professur für elektrische Hochspannungstechnik“ GmbH
Landsberger Allee 278A
10881 Berlin, GERMANY

DATES OF TESTS: 02 September to 08 October 2008

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this certificate has been subjected to the series of proving tests in accordance with:

IEC 60081-2: 2000-10, Sub-clauses 8.2.1, 8.2.2, 8.2.3, 8.2.4.2, 8.2.5, 8.2.6, 8.2.7, 8.2.8, 8.2.9, 8.2.10, 8.2.12, 8.2.15, 8.2.16 and 8.2.18

The results are shown in the record of Proving Tests and the photographs attached hereto. The values obtained and the general performance are considered to comply with the above Standards and to justify the ratings assigned by the manufacturer on rated basis.

For ratings assigned by the manufacturer and proved by test see Pages 1 and 2.

The record of Proving Tests applies only to the apparatus tested. The responsibility for conformity of any assembly having the same designations with the tested one with the Manufacturer.

This Certificate comprises: 03 pages, 1 diagram, 0 photographs, 10 programs, 0 drawings and no other sheets.

This is a true and correct copy of the Certificate, or reproduction of the copy, accompanied by the pages on which are stated the assigned rated characteristics of the apparatus tested, are permitted without payment, from ASTA 2000 Certification Services, 1000 New, Corporate Drive, Suite 1000, 2000 New, Washington.



[Signature]
17th Jan 2009

ASTA Chairman
J. Haring
Certification
Manager

Date