



APPROVED FOR LA CERTIFICATION
GLOBAL APPROVALS AND CERTIFICATION

Via Tito Livio, 3 - 24121 - BERGAMO (Italy)
Tel: +390354715244 fax: +390354734552 e-mail: acae@acae-cert.it



Certificate of Conformity

LOVAG-Certificate No. IT 14.084

Page 1 of 2

This certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designation with that tested rests with the manufacturer or responsible vendor.

This certificate has been prepared according to LOVAG (Low Voltage Agreement Group) Objectives and Operating Principles of mutual recognition.

The responsible certification body as member of LOVAG issues a Certificate of Conformity with the above mentioned Standard(s) following the extensive use of LOVAG Test Instructions whenever applicable.

Only integral reproduction of this Certificate or reproductions of this page accompanied by any paper(s) on which are stated the tests performed and the assigned related characteristics of the apparatus Tested, are considered without written permission from the LOVAG responsible for this Certificate.

Apparatus: Low-voltage busbar trunking system 690V (U_N) - 40A (I_{max}) - 10Hz (f) - 1000V (U_0) - 3,5kV (U_{imp}) - 3,5kA, Ia (I_{sc}) - 5,23kA (I_{ph}) - IP55
5 Copper Wires (3P+N+PE) and Aluminium Housing (E)

Designation: GNL 25-40A

Manufacturer or responsible vendor:

GERSAN ELEKTRIK TIC. ve SAN. A. S.
Anadoluh Yakası Organize Sanayi Bölgesi Gazı Bulvarı No. 39-41 - P.K. 57
34953 TUZLA - ISTANBUL (Turkey)

Applicant: GERSAN ELEKTRIK - ISTANBUL (Turkey)


Tested by: VEIKI-VNL - BUDAPEST (Hungary)

The apparatus, constructed in accordance with the description mentioned in the documents listed on this Certificate has been subjected to the series of proving tests in accordance with IEC 60439-2 (2005-10).

The results of the tests carried out fulfill the requirements of the relevant parts of IEC 61439-4 (2012-05), according to sub. 16.1 of IEC 61439-1 (2009-01).

The results are shown in the Test Report in accordance to LOVAG. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the characteristics assigned by the manufacturer as stated below.

Responsible Certification Body : ACAE
Virginia Scarlat



PRO. WITOLD
Secretary of CA, IAF and ILAC
Mutual Recognition Agreements

Virginia Scarlat

Authorized signature

Date: 2014.09.15